



Jar Testing Methodology

21st, 22nd, 23rd March 2017
Location: Various .

Kevin Love

Irish Water



Introduction

- Introduction
- General Background
 - Why Regular Jar Testing is Essential
 - Know what you want to get out of your jar tests
 - Essential Equipment Required
- Jar Test Procedures
 - Basic Principals same for each method
 - Jar Test Template Examples
- IW Jar Test Specification
 - Section 3. Jar Test Methodology
 - Analysis
 - Interpretation of Results
- Raw Water Requiring Alkalinity Correction
 - Worked Examples
 - pH Correction proportional to coagulant dose
- Consistence in Stock Solutions
 - Preferably use a micro pipette
 - Making stock solutions where micropipettes are not available
- Floc Size Comparator
- Mg/l as product of mg/l Al/Fe
- Applying jar test findings onto a plant
- Trend Jar Test Results
 - Automatic Coagulation

General Background

- The fundamental aim of jar testing is using bench scale testing to simulate / duplicate conventional treatment steps of a full-scale plant
- It is important that the conditions used in the jar test accurately simulate full-scale plant conditions as possible. Knowledge of the water treatment plants hydraulic characteristics for initial mixing / flash mixing, flocculation, and clarification are all critical (as well as translation into a batch-testing protocol). The parameters include:
 - Effective retention times in the rapid mix and flocculation basins
 - Actual retention time in basins if jar testing is being done to evaluate time dependent reactions for which full-scale reaction time influences results

Why Regular Jar Testing is Essential

- Maximum Removal of Organics
 - Reduced THM Formation
- Reduced Risk of Cryptosporidium
- Chemical Efficiency
- Optimum Clarification Process Performance
- Reduced Solids loading on to filters
 - More efficient filter runs
- Reduced Chlorine Demand
- Maintain Chlorine Residuals Longer in Network Distribution

Know what you want to get out of the Jar test

- Chemical Response to Changes in Raw Water Quality or Characteristics
- Evaluation on the effects of changes in chemical dosages and points of application;
- Choose alternative coagulants;
- Addition polymeric coagulant aids (including evaluation at different timing point and locations);
- Variation of mixing intensities and times; and
- Evaluation on removal of total organic carbon, or other water quality parameters of concern (i.e. colour, turbidity, soluble/insoluble metals).

Equipment Required/Desirable

Item	Function
Flocculator/Jar Test Unit	6 No. jar testing unit recommended with variable speed stirrer settings (0-300rpm) and a stop watch.
6 x 500 or 1000ml Beakers (low style) (flocculator depending)	Glassware to carry out jar tests.
3 x 500/1000ml Beakers and additional glassware (1 litre and 500ml measuring cylinders) as required for filtration and sample collection	Raw water sample collection and for collecting filtered samples.
Micro-Pipette (10-100 µl and 1-20 µl) and dispensing tips RECOMMENDED	For dosing neat chemicals. Note: Chemical dilution should be avoided. Dilution can lead to degradation of active product and also dilution errors.
Pipettes (1ml, 5ml and 10ml) and suction pump	For dosing diluted chemicals
Whatman No.1 Filter Paper (30-50cm dia.) (Alternate porosity filter paper should be applied if filter media porosity known to be different)	Simulates similar filtration capability of rapid gravity filters. Porosity approximately 11µm. A suction filter could also be considered for jar test filtration as gravity filtration can be time consuming. Care should be taken not to damage or rip filter paper.
2 x larger filter funnels and funnel stand	For filtration of coagulated and flocculated samples
50, 10 and 1 ml syringes	For abstracting samples from beakers to fill bench instrument sample cells. Decanting is often difficult direct from beakers.
0.45 µm membrane discs	For filtering samples to measure true colour, dissolved metals, UVA or DOC only.
Turbidity meter (with sample bottles and cleaning oil)	Turbidity measurements. Periodic calibration to manufacturer standards recommended.

Equipment Required/Desirable (Contd.)

Photometer and Colorimeter	For measuring colour, total metals (iron, aluminium or manganese – site specific). Suitable reagents as recommended by manufacturer instructions should be purchased in advance of any tests.
pH meter (and standard solutions for calibration – buffers pH 4, 7 and 10)	Measuring pH change and preparing jars to a fixed pH for enhanced coagulation tests. Ensure pH probes are properly maintained, stored in the correct ionic strength potassium chloride buffer solution and calibrated frequently to a minimum of 2 points (pH 4 and pH 7). Probes should never be stored in deionised water or bulbs allowed to dry out.
Magnetic stirring plate and stirrer flea	Mixing and preparing samples (i.e. polyelectrolytes, lime slurry and soda ash).
Electronic balance scales	Weighing – recommended to use a calibrated device to 3 decimal places.
Sample bottles and labels from analytical labs	Samples that are considered to be optimised from jar tests and works sample points should be compared and evaluated for a given set of parameters.
Coagulant solution	Aluminium sulphate, polyaluminium chloride, ferric sulphate, ferric chloride - <u>All neat coagulant solutions should where possible be taken from site storage tanks and replaced on a weekly basis.</u> It is recommended that MSDS from chemical suppliers be obtained in advance of any tests from Irish Water or chemical supplier.
pH adjustment chemicals (For all chemicals it is essential to note concentration (% w/w) and specific gravity.)	Caustic soda (sodium hydroxide), soda ash (sodium carbonate – may require batching (5% w/w recommended), lime (for lime slurry 1.5% w/w recommended), sulphuric acid, hydrochloric acid. Maintain good laboratory practice and keep acid and bases separate in a chemical safe box. All bottles should be clearly labelled and dated.
Polyelectrolyte	<u>Poly solution where possible should be sampled daily or every other day from site day tanks.</u> Alternatively, powder solutions should be carefully prepared to 0.1 – 0.2% w/v (or equivalent plant strength) every other day.

Jar Test Procedure



Irish Water

ENGINEERING SPECIFICATION: CFC EVALUATION AND JAR TESTING (CLEAN WATER)

Document No: IW-TEC-XXX-XX

Revision: 0.1 (2016)

Irish Water Jar Test Specification

ID No.: OP23/W11		Drinking Water			Date: Aug 08	
Rev: 3		Selection of Coagulant and Flocculant Dose Rates			Page 1 of 1	
Approved by:		Eamon Nunan				
Stage A: Determination of raw water characteristics.						
Measure pH, TDS, colour (true and apparent), turbidity, alkalinity, UVA, UVT and temperature.						
Stage B: Preparation of Working Solutions.						
Coagulant:	Prepare a 1:10 w/v dilution of coagulants from commercial products using treated water where possible. Prepare daily. By weight: 10gms dissolved in 100 mls of water. By volume: mls of liquid coagulant made up to 100mls					
	Liquid Alum	Ferric Sulphate	Ferric Sulphate HA	Chemifloc 101	Chemifloc 103	PAC
	7.6	6.5	7.0	7.4	7.7	8.3
	1 ml of working solution = 100mg (ppm) of Product.					
Flocculant:	Prepare a 1g/l solution of the flocculants by dissolving 0.2 gm in 200 mls of D.I. Water. Allow to mix for 40 minutes. Prepare daily. 1 ml of working solution = 1mg (ppm) of Product					
pH Control:	1N Sulphuric Acid solution;		1 ml added to 500 mls of water = 98 mg/L.			
	1N Sodium Hydroxide Solution;		1 ml added to 500 mls of water = 80 mg/L.			
	10% w/v Soda Ash Solution;		1 ml added to 500 mls of water = 200 mg/L.			
Stage C: Determination of best dosage of coagulant.						
<ol style="list-style-type: none"> 1) Pour 500 mls of raw water into beakers and place on gang stirrer. 2) Agitate at 200 rpm. 3) Add required coagulant dose to each beaker (Range 40 – 260 mg/L) by injecting 0.1 mls of working solution for every 20 mg/L required. 4) Agitate at 200 rpm for 2 minute. 5) Agitate at 30 rpm for 13 minutes. 6) Determine the optimum dose and coagulant by visual appreciation of growing flocs during slow agitation phase. 7) Monitor pH values after addition of coagulant and determine pH adjustment dosage as required. 8) Repeat evaluation until the optimum coagulant, dose rate and coagulation pH has been determined. 9) Run test at the required pH and coagulant dose rates. 10) Evaluate and record the level of floc formation. 11) Allow to settle for 30 minutes and record settlement rates. 12) Filter supernatant using a No. 40 Whatman filter paper and test for turbidity. 13) Filter supernatant using a 0.45µm filter and test for colour, UVA, UVT and dissolved metal i.e. Aluminium, Iron. 						

Chemifloc Jar Test Procedure



Basic Principles Same for Each Procedure

- Pour 500ml/1000ml Raw Water into 6 Beakers
- Turn Flocculator on to 200 rpm
- Add the required amount of pH Correction Product
- Add the desired Amount of Coagulant (60-200ppm)
 - One jar should be used to reflect current plant set points for comparison/reference
- Allow to mix for 1-2 mins dependant on local site conditions
- Reduce Flocculator Speed to 30 rpm
- Allow to mix for 15 mins
- Record Flocculation pH
- Switch of Flocculator and Allow to stand for 30 minutes
- Draw of supernatant and test for turbidity as an indication of the clarification process
- Draw of supernatant from the beaker, filter through a 1.0 um syringe filter and test for UVA, UVT and Residual Coagulant
- Select dose that gives maximum organic carbon removal (Highest UVT) or Lowest Turbidity

Jar Testing Template Examples

Plant Name:		Date:													
Technician:		Time:													
Raw Water Analysis:															
Raw Water Sample taken from:															
Raw water THMFP (µg/l)															
RAW WATER DATA		Colour		Chemical											
Temp.	pH	Alkalinity	Apparent	True (0.45µm filtered)	Turbidity	Iron	Manganese	TDS	UVT (0.45µm filtered)	TOC (if known)	DOC (if known)	Conductivity	WTP coagulant dose (if known)	WTP poly dose (if known)	WTP dosed raw water pH (if known)
°C		mg/l	PCo	PCo	NTU	ug/l	ug/l	mg/l	%	mg/l	mg/l	us/cm	mg/l	mg/l	pH
Beaker No.		1	2	3	4	5	6	Target							
Initial Jar pH															
Coagulant		Aluminium Sulphate 8%													
Coagulant Dose as product (mg/l)		80	90	100	110	120	130								
pH Adjustment Product		Sulphuric Acid 96%													
pH Adjustment Dose (mg/l)															
pH measured		6.0	6.1	6.2	6.3	6.4	6.5								
Polyelectrolyte		Flopam AN 910													
Poly Dose (mg/l)															
Poly Dose time after coagulant addition (mins)															
Rapid Mixing and Flocculation Mixing															
Rapid Mix Time (mins)															
Slow Mix Time (mins)															
Floc Size from Chart at end of Slow Mix Time															
Settlement Time (mins)															
Settled Water Analysis															
Colour (PCo) Settled															
Turbidity Settled Water (NTU)															
Aluminium (Total) Settled (ug/l)															
Iron (Total) Settled (ug/l)															
Manganese (Total) Settled (ug/l)															
Alkalinity Settled (mg/l CaCo3)															
Filtered Water Analysis (Whatman No. 1 Filtered)		5.0	4.5	4.0	2.0	3.0	4.0	<5							
pH measured															
Residual Aluminium (ug/l)		50.0	40.0	20.0	25.0	30.0	35.0	<200							
Residual Iron (ug/l)															
Manganese (ug/l)															
UVT (%)		88.0%	89.0%	90.0%	93.0%	88.0%	87.0%	>92							
Turbidity NTU		0.29	0.27	0.20	0.10	0.15	0.24	<0.2							
TOC (mg/l)															
DOC (mg/l) (0.45µm filtered)															
% TOC Removal		#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!								
THMFP															
Selection of Optimum Dose is Based on the Following Assumptions. 1) Highest Filtered Water UVT, Lowest Filtered Water Iron/Alum Residual, Lowest Filtered Water Turbidity.															
Pump Settings															
Plant Flow (m3/hr)		200	pH correction Concentration		g/l										
Optimum pH Control mg/l		50	Coagulant Concentration		1835										
Optimum coagulant mg/l		110	Coagulant Concentration		1320										
Optimum Poly Dose mg/l		0.1	Poly Day Tank Solution		1										
Calculate Pump Flow Rate (Flow in m ³ /Dose in hr*mg/l)/Concentration g/l = l/hr															
pH Control l/hr		5.4	pH Adjustment Pump Stroke		Speed										
Coagulant l/hr		16.7	Coagulant Pump Stroke		Speed										
Poly l/hr		20.0	Poly Pump Stroke		Speed										

Coagulant dose versus Colour (PtCo)

Aluminium Sulphate 8%

pH change versus Colour (PtCo)

Aluminium Sulphate 8%

Coagulant dose versus Turbidity (NTU)

Aluminium Sulphate 8%

pH change versus Turbidity (NTU)

Aluminium Sulphate 8%

Coagulant dose versus Metal Residual

Aluminium Sulphate 8%

pH change versus Metal Residual

Aluminium Sulphate 8%

Irish Water Jar Testing Specification Template

Appendix 1

Jar Test Record Sheet

Date:	12/10/16	Weather:	Dry/sunny
Plant Name:	Achill Water Treatment Plant		
Raw Water Source:	Lough Acorrymore		

Raw Water Analysis

Temperature °C	pH	Alkalinity mg/L CaCO ₃	Colour		Turbidity NTU	Conductivity µs/cm	TDS mg/L	UVA	UVT %
			Apparent PtCo	True PtCo					
16.4	5.5	<5	54	46	0.72	112	112	0.243	57.1

Jar Test 1					
Beaker No	1	2	3	4	
Alum Dose (mg/L)	60	70	80	90	
Soda Ash Dose (mg/L)	45	53	60	68	
Poly Dose (mg/L)	0.1	0.1	0.1	0.1	
Floc Size	Pin	Medium	Medium	Medium	
Floc pH	6.39	6.63	6.66	6.75	
Settled Water Analysis					Jar Test Target
Alkalinity (mg/L CaCO ₃)	10	15	20	20	
Apparent Colour (PtCo)	4	2	0	0	<20
Turbidity (NTU)	0.44	0.35	0.32	0.32	<1
Filtered Water Analysis (0.45µm)					
Aluminium (µg/L)	20	24	22	23	<50
True Colour (PtCo)	Under Range				<5
Turbidity (NTU)	0.11	0.13	0.09	0.09	<0.2
UVA	0.013	0.014	0.013	0.014	
UVT (%)	96.8	96.7	96.9	96.8	>90

Achill WTP. Mayo County Council.



JAR TEST SHEET

COS Water Treatment Plant
Raw Water Source River Shannon

Date: 24/01/2017

Jar No.	1	2	3	4	5	6	
Caustic Dose (mg/L)	0	0	0	0	0	0	
Rapid Mix 30 sec							
Alum Dose (mg/L)	170	180	190	200	210	220	
Poly Dose (mg/L)	0.18	0.18	0.18	0.18	0.18	0.18	
Floc pH	6.86	6.72	6.67	6.63	6.63	6.61	
Rapid Mix 2 min (Approx 250 revs)							
Slow Mix 15 min (Approx 25 revs)							
Settle 15 min	NTU	1.65	1.36	1.59	1.75	1.62	1.87
Filter through 0.45micron filter							
Raw Water							
Alkalinity (mg/L)	98.4						
Colour (True-Filtered)	83						
Colour (Apparent)	97						
pH	7.95						
Turbidity (NTU)	2.3	0.15	0.11	0.16	0.12	0.12	0.14
UVT (%)	37.2	81.6	82.3	83.1	84.1	85.4	85.9
Aluminium							

Carrick on Shannon. Leitrim County Council

Flocculation Test

Location: _____ Date: _____

Raw Water Quality:-

• Colour		TOC		True Col	
• pH		DOC		App Col.	
• Temp				UV Trans	
		Alkalinity		UV Abs	

<u>Beaker No.</u>	Soda/Lime	Alum	Poly	Floc	pH	Res. Alum	DOC	UV Trans	UV Abs	Remarks	TOC %Removal
1											
2											
3											
4											
5											
6											

Add Soda - 300 RPM for 1 min.
 Add Alum- 100 RPM for 30 sec.
 Ad Poly - 100 RPM for 30 sec, 35 RPM for 5 min & 19 RPM for 10 min.

Current Dose.	
Soda -	
Alum -	
Poly -	
pH	

Irish Water Jar Testing Specification

Raw Water Sample taken from:											
Raw water THMFP (µg/l)											
RAW WATER DATA			Colour			Chemical					
Temp.	pH	Alkalinity	Apparent	True (0.45µm filtered)	Turbidity	Iron	Manganese	TDS	UVT (0.45µm filtered)	TOC (if known)	DOC (if known)
°C		mg/l	PtCo	PtCo	NTU	ug/l	ug/l	mg/l	%	mg/l	mg/l
Beaker No.					1	2	3	4	5	6	Target
Initial Jar pH											
Coagulant	Aluminium Sulphate 8%										
Coagulant Dose as product (mg/l)					80	100	110	120	130		
pH Adjustment Product	Sulphuric Acid 96%										
pH Adjustment Dose (mg/l)											
pH measured					6.0	6.1	6.2	6.3	6.4	6.5	
Polyelectrolyte	Flopam AN 910										
Poly Dose (mg/l)											
Poly Dose time after coagulant addition (mins)											
Rapid Mixing and Flocculation Mixing											
Rapid Mix Time (mins)											
Slow Mix Time (mins)											
Floc Size from Chart at end of Slow Mix Time											
Settlement Time (mins)											
Settled Water Analysis											
Colour (PtCo) Settled											<20
Turbidity Settled Water (NTU)											<2
Aluminium (Total) Settled (ug/l)											
Iron (Total) Settled (ug/l)											
Manganese (Total) Settled (ug/l)											
Alkalinity Settled (mg/l CaCo3)											
Filtered Water Analysis (Whatman No. 1 Filtered)											
Colour (PtCo)					5.0	4.5	4.0	2.0	3.0	4.0	<5
pH measured											
Residual Aluminium (ug/l)					50.0	40.0	20.0	25.0	30.0	35.0	<200
Residual Iron (ug/l)											<200
Manganese (ug/l)											<50
UVT (%)					88.0%	89.0%	90.0%	93.0%	88.0%	87.0%	>92
Turbidity NTU					0.29	0.27	0.20	0.10	0.15	0.24	<0.2
TOC (mg/l)											
DOC (mg/l) (0.45µm filtered)											
% TOC Removal					#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!
THMFP											

Selection of Optimum Dose is Based on the Following Assumptions. 1) Highest Filtered Water UVT, Lowest Filtered Water Iron/Alum Residual, Lowest Filtered Water Turbidity.

Variations in Raw Water Quality

Optimum Flocculation pH

Floc Size, Settleability and Turbidity Removal

Best Organic Carbon Removal

- Highest UVT

Lowest Filtered Water Turbidity

Residual Alum/Iron < 50ug/l

Irish Water Jar Testing Spec.



Irish Water

ENGINEERING SPECIFICATION: CFC EVALUATION AND JAR TESTING (CLEAN WATER)

Document No: IW-TEC-XXX-XX

Revision: 0.1 (2016)



TABLE OF CONTENTS

Record of Changes and Ammendments	2
Foreword	3
1. Purpose and Review For Coagulation, Flocculation and Clarification (CFC)	6
2. General Background	8
2.1. Jar testing - Defining study Goals	8
Disinfection By-products	12
THM Formation Potential (THMFP)	13
2.2. Jar Testing Preliminaries	14
Laboratory practice and health and safety	14
Recommended equipment	15
2.3. Coagulant properties and pH set points	18
Alkalinity	18
Chemical conversions	21
pH measurements	22
Expressing chemical concentrations	22
Preparing chemical dilutions	23
Point of chemical additions	23
Polymer addition	24
advice and guidance for raw water sampling requirements	24
3. Jar Testing Methodology	26
Jar test Preparation	27
Optimal pH jar tests	28
Optimal coagulant dose jar tests	30
Optimal polymer dose jar tests	33
3.1 Results and interpretation	34
Point of Diminishing Returns (PODR)	34
Jar Test Report	35
4. Raw Water Quality Monitoring for existing or new plants	36
Raw Water Monitoring Programme of Works	36
Works inlet raw water and bench analysis as part of bench testing and sampling at a water treatment plant	37
Suggested water quality parameters for laboratory analysis	38
References	39
Bibliography	39
Appendix A Floc Size Determination	40
Appendix B Jar Testing Record Sheet Template	41



3. JAR TESTING METHODOLOGY

- Jar Test Preparation
 - Sample Collection
 - Raw Water Analysis
 - Preparation
- Optimal pH jar tests
 - Add Coagulant First
 - Addition of pH Correction Product to target pH 6.0,6.2,6.4.....
- Optimal Coagulant Jar Tests
 - Once optimum pH has been established
 - Vary Coagulant Dose
- Optimal Polymer Jar Tests
 - Polymer Selection
 - Different time intervals after addition of coagulant.

Analysis

FILTRATE BENCH ANALYSIS

- Carefully decant settled jar test water and pass through a 1 μ m filter paper and collect filtrate for analysis (to simulate RGF filtration stage). Measure for filtered colour, turbidity, UVT and **aluminium/iron/manganese residuals as applicable**.
- Further filter this primary filtrate through a 0.45 μ m filter and test for true colour, UVA, UVT and dissolved metals (if required).
- Tabulate and plot results to ascertain lowest metal and turbidity residuals. If there are several points which show equally low metal and turbidity residuals select the point with the lowest metal dose.

3.1 RESULTS AND INTERPRETATION

- Optimise and understand the conditions for coagulant dosing and pH adjustment requirements for best organics/natural organics removal. UVT is considered an excellent indicator of coagulation performance. Effective coagulation, flocculation and clarification is also essential to ensuring that a UVA of 0.035cm^{-1} (92% UVT) is achieved in filtered water, thus removing the potential for disinfection by-product formation;
- Evaluate the potential for THM formation; and
- Understand the potential chlorine demand requirements of treated water to reflect on the likely THM formation and chlorine decay in extended supply networks.

Raw Water Requiring Alkalinity Correction

- Alkalinity Consumption

1.0 mg/l of Product	mg/l Alkalinity as CaCO ₃ (F)
Liquid Aluminium Sulphate	0.24
Kibbled Aluminium Sulphate	0.51
Ferric Aluminium Sulphate	0.25
Ferric Sulphate Solution 12% w/w Fe	0.32
PolyAluminium Chloride	0.147

- Alkalinity Addition

1.0 mg/l of Product	mg/l Alkalinity as CaCO ₃
Sodium Carbonate as Na ₂ CO ₃	0.94
Sodium Hydroxide as NaOH	1.25
Sodium Hydroxide as 25% w/w NaOH	0.312
Sodium Hydroxide as 30% w/w NaOH	0.375
Hydrated Lime as Ca(OH) ₂	1.35

- Alkalinity Suppression

1.0 mg/l of Product	mg/l Alkalinity as CaCO ₃
Sulphuric Acid 96%	0.98
Sulphuric Acid 50%	0.49
Sulphuric Acid 30%	0.30

Worked Example of Alkalinity Correction

- Raw Water 15mg/l Alkalinity
 - Optimum Jar Test Alum Dose = 120mg/l
 - Target Residual Alkalinity 10-20mg/l
 - Alkalinity Correction Required for Optimum Coagulation is:
 - $(120 \times 0.24) + 20 - 15 = 33.8 \text{ mg/l}$
 - 1mg/l Sodium Carbonate = 0.94 mg/l Alkalinity; Required Soda Ash Dose is $33.8 / 0.94 = 36 \text{ mg/l}$

- For Sites with Raw Water Alkalinity Requiring Suppression
 - Add suggested range of alum (100-200mg/l)
 - Add Sulphuric Acid until target pH is met
 - Convert mls of acid used to mg/l
 - E.g. 8.4mls of 5g/l stock solution added to 500ml
 - 84mg/l Sulphuric Acid Dosed to meet target pH

pH Correction Proportional to Coagulant Dose

- Variable Coagulant Dose and Fixed pH Correction

	1	2	3	4	5	6
Alum	60	80	100	120	140	160
Soda Ash	30	30	30	30	30	30
pH	6.65	6.50	6.35	6.20	6.15	5.90

- Variable Coagulant Dose and Fixed pH Correction

	1	2	3	4	5	6
Alum	80	80	80	80	80	80
Soda Ash	25	30	35	40	45	50
pH	5.84	6.02	6.2	6.38	6.56	6.74

- pH/Alkalinity Elevation Proportional to Coagulant Dose

	1	2	3	4	5	6
Alum	60	80	100	120	140	160
Soda Ash	20	25	30	35	40	45
pH	6.18	6.21	6.19	6.20	6.14	6.07

- pH/Alkalinity Suppression Proportional to Coagulant Dose

	1	2	3	4	5	6
Alum	60	80	100	120	140	160
Sulphuric Acid	75	70	65	60	55	50
pH	6.1	6.09	6.12	6.06	6.12	6.08

Consistency in Stock Solutions

Examples of Stock solution used:

10g/l stock solution with 500ml beakers

- 1ml of this equals 20mg/l coagulant dose

1ml of product into 500ml equals 25mg/l

- 12.5g/l solution
- Requires calculation if you're looking for 80mg/l (3.2ml)

- For consistency stock solutions should be:

- 5g/l Stock Solution Strength for 500ml Jars or 10g/l Stock Solutions for 1L Jars
 - Where 1ml of each stock solution equals 10 mg/l
 - Avoids factoring up/down dependent on stock solution Strength
- This applies to all pH correction product and coagulants.

- Polyelectrolyte is the exception:

- Required Stock Solution is 0.05g/l for 500ml Jars and 0.1g/l for 1L Jars
 - Where 1ml of each stock solution is 0.1mg/l

Preferably use a micro-pipette



Range of pipettes available

8% Liquid Alum

60mg/l = 22.73µl

80mg/l = 30.30µl

100mg/l = 37.88µl

120mg/l = 45.45µl

140mg/l = 53.03µl

5% Soda Ash

5mg/l = 50µl

10mg/l = 100µl

15mg/l = 150µl

20mg/l = 200µl

25mg/l = 25µl

0.1% Poly

0.1mg/l = 50µl

0.15mg/l = 75µl

0.2mg/l = 100µl

All uls listed are for 500ml samples. X2 for 1L Beakers

E.g. 100mg/l Alum Dose

$$\frac{100\text{mg/l} * 500\text{ml}}{1320000\text{mg/l}} = 0.0227\text{ml}$$

1320000mg/l

Or 22.73 µl

Making Stock Solutions

Target 1ml of stock solution is equal to 10mg/l of product for coagulation and pH correction

- Required strength to achieve this is **5g/l** or (5000mg/l) for 500ml jars (10g/l for 1 litre jars)

$$\text{Calculation for } \mathbf{5g/l}: \frac{1\text{ml} * 5000\text{mg/l}}{500\text{ml}} = 10\text{mg/l}$$

$$\mathbf{10g/l} \text{ Solution } \frac{1\text{ml} * 10000\text{mg/l}}{1000\text{ml}} = 10\text{mg/l}$$

- To make up a 5g/l solution of alum as **coagulant** put 3.78ml into a volumetric flask and make up to 1 litre

$$\frac{5\text{g/l} * 1000\text{ml}}{1320\text{g/l}} = 3.78\text{ml}$$

$$\text{Ferric Sulphate 120} = 1550\text{g/l i.e. } 3.22\text{ml}$$

$$\text{PACL (10\%)} = 1205\text{g/l i.e. } 4.149\text{ml}$$

$$\text{Chemifloc 101} = 1356 \text{ g/l i.e. } 3.678\text{ml}$$

- To make up a 5g/l solution of soda ash for **pH correction** put 100ml from day tank into a volumetric flask and make to 1 litre (assuming a 5% solution)

$$\frac{5\text{g/l} * 1000\text{ml}}{50\text{g/l}} = 100\text{ml}$$

- Sulphuric Acid and Caustic Soda is made up similar to alum at 5 g/l and using the following g/l strengths:

- 96% Sulphuric Acid 1835g/l

- 50% Sulphuric Acid 1395g/l

- 30% Caustic Soda 1330g/l

- 25% Caustic Soda 1275g/l

- To make up a 0.05g/l solution of **polyelectrolyte** put 50 ml from day tank into a volumetric flask and make to 1 litre (assuming a 0.1% solution)

$$\frac{0.05\text{g/l} * 1000\text{ml}}{1\text{g/l}} = 50\text{ml}$$

$$\frac{1\text{ml} * 50\text{mg/l}}{500\text{ml}} = 0.1\text{mg/l}$$

Floc Size Comparator




Figure 16: Comparator for the Evaluation of Floc Size Index in Coagulation Tests

Risk: Good floc formation but poor organic carbon removal
Filter Supernatant and analyse for optimum dose over visual Assessment

mg/l as Product or mg/l as Al or Fe

- How to convert from mg/l Al to mg/l product.

Product	Chemical formula	% alumina content as Al ₂ O ₃	% Al content	% Fe content	spec grav
Liquid Aluminium Sulphate 8%	Al₂(SO₄)₃nH₂O	8.25	4.25	0.00	1.32
Chemifloc 103	Al ₂ (SO ₄) ₃ nH ₂ O.nH ₂ SO ₄	6.00	3.00	0.00	1.29
Polyaluminium Chloride 10%	Al _n (OH) _m Cl _{3n-m}	10.00	5.00	0.00	1.21
Chemifloc 101	xAl ₂ (SO ₄) ₃ .(1-x)Fe ₂ (SO ₄) ₃ .nH ₂ O	-	4.00	3.20	1.35
Ferric sulfate 12%	Fe ₂ (SO ₄) ₃ .nH ₂ O	0.00	0.00	12.00	1.50
Ferric chloride	FeCl ₃ .nH ₂ O	0.00	0.00	13.10	1.40

E.g. Liquid Aluminium Sulphate 8%

Percentage Alum Content is 4.25%

$100/4.25 * \text{mg/l Al} = \text{mg/l Product}$

$23.5 * 4.55\text{mg/l} = 100\text{mg/l}$

Conversion factors (mg/l)	
Al ₂ O ₃ to Al ³⁺	÷ 0.5294
Aluminium Sulphate liquid to Al ³⁺	÷ 23.6111
Fe ₂ (SO ₄) ₃ to Fe ³⁺	÷ 8.3333
FeCl ₃ to Fe ³⁺	÷ 6.8965
Fe ³⁺ to Al ³⁺	÷ 2.0666

Application of jar tests results onto the plant

Optimum Alum dose identified 100 mg/l

Plant Flow Rate 350 m³/hr

Specific Gravity of Alum = 1.32 or 1320g/l


Pump Dosing Rate = $\frac{350\text{m}^3/\text{hr} * 100\text{mg/l}}{1320\text{g/l}} = 26.5\text{l/hr}$

26.5l/hr = 441 mls/min.

Perform Pump Draw Down

Monitor:

- Flocculation pH on site
- Clarification Process Outlet Turbidity
- Filtered Water Turbidity
- Final Water UVT




Multiple Jar Test Results -v- Time

- Use historical jar tests as a prediction of future doses based on raw water organics
- Plot Raw Water UVT/UVA -v- Alum Dose
- Plot Optimum Alum Dose -v- Flocculation pH
- Plot Optimum alum dose -v- Filtered Water UVT/Turbidity

Outcome: Eventual Feed Forward Coagulant Dosing Curve based on raw water UVT/UVA or TOC

Examples of Automatic Coagulant Dosing Curves


Carrick on Shannon Automatic Alum Dosing Curve



SAC m-1	Corrected Dose mg/l Al	Corrected Dose mg/l Product
5	2	47.2
15	5	117.9
30	8.0	188.7
35	8.5	200.5
38.4	9.0	212.3
42	9.2	217.0
47.1	9.4	221.7
53.6	9.8	231.1
57.3	10.2	240.6
57.9	10.3	242.9
61.7	10.5	247.6
76.5	11.0	259.4
100	12.5	294.8
121.6	13.5	318.4
150	18	424.5

Swinford Automatic PACL Dosing Curve

SAC	mg/l
0	0
3	0.9
4	1.3
5	1.6
10	3.09
15	4.4
20	5.6
25	6.6
30	7.5
35	8.2
40	8.75
45	9.17
50	9.42
55	9.51



Jar Test Tables and Graphs for Interpretation

Water Test Sheet

Location	Raw Water Source	Tested by:	Date
Carrick on Shannon WTP	River Shannon	Eamon Nunan	19/03/2015

Parameter	Coagulation Test 1					
	Jar 1	Jar 2	Jar 3	Jar 4	Jar 5	Jar 6
pH Control						
Dose as mg/l						
Coagulant						
Dose as mg/l						
Flocculant						
Dose as mg/l						
Notes						
pH						
Temperature °C						
Total Dissolved Solids as mg/l						
Alkalinity as mg/l CaCO ₃						
True Colour as units PtCo						
Apparent Colour as units PtCo						
Turbidity as NTU						
UV Abs 254nm						
UVT as %						
Total Organic Carbon as mg/l C						
Dissolved Organic Carbon as mg/l C						
SUVA as L/mg-m						

