



The Provision of Safe and Secure Drinking Water

Drinking Water Safety Challenge



Asset Planning (Water Treatment)

March 2017

V0 3

Coagulation Control Workshop - Agenda

09h00 – 09h30: Registration

09h30 – 10h15: [Provision of safe drinking water](#) [Victor van der Walt, IW]

10h15 – 11h00: [Coagulation chemistry](#) [David Speers, Jacobs]

11h00 – 11h30: Tea/Coffee



11h30 – 12h15: [Jar testing best practice](#) [Kevin Love, IW]

12h15 – 13h00: [History of coagulation control](#) [John Clark, Chemtrac]

13h00 – 14h00: Lunch



14h00 – 15h00: [CoagSense Coagulation Control](#) [John Clark, Chemtrac]

15h00 – 16h00: [Practical Implications of Coagulation Control](#) [Mike Riding, PI]

Traditional approach (monitoring the end product)

- Monitoring of coliform bacteria, turbidity and disinfectant residuals has been demonstrated insufficient for the prevention of waterborne outbreaks (Payment *et al.*, 1993)
- Waterborne outbreaks have been documented in regions where the drinking quality was met with existing microbiological criteria (Melnick and Gerba, 1979; Craun, 1981; Lippy and Waltrip, 1984; O'Neil *et al.*, 1985)
- The presumed close correlation between pathogen occurrence and the detection of indicator organisms may not always be present, especially in the case of *Cryptosporidium* (Teunis *et al.*, 1995)



New approach required

Galway (EPA 2012)


- *Outbreak of Cryptosporidium in Galway City in 2007 (242 cases of illness)*
- *Compliance with micro, chemical and indicator parametric values was 99.1% the previous year.*
- *Monitoring did not tell us whether the supply was safe and secure*

HOW

Drinking Water Safety Challenge cont.

New approach (health based targets and microbial risk assessment)

- New WHO approach focuses explicitly on **risks posed by waterborne pathogens in individual sources** of drinking water (WHO Guidelines for drinking water quality, 4th ed., 2011)



Drinking Water Safety Plan approach

212° the extra degree

At 211 °F, water is hot
At 212 °F, water it boils,
And with boiling water, comes steam.
And steam can power a train

**AND ... IT IS THAT
ONE EXTRA DEGREE**


that makes all the difference!

(Sam Parker, 2005)

DWSP Approach - by making small changes
we can significantly improve the safety and
security of drinking water we supply!

HOW

WHO Risk Assessment and Risk Management Approach – a new way of working



Development/implementation of risk-based approach:

- Australia, Canada, Netherlands, New Zealand, Sweden, Norway, USA

Implementation challenges [UKWIR, 2016]:

- Recognised that a **health target is not practical** for assessing the microbiological safety of drinking water. Instead it has been **converted to a performance target for water treatment**, (i.e. specified log reductions for particular pathogens).
- Limited to assessing robustness of water treatment processes. **No corresponding assessment for water in distribution systems.**
- **Log reduction targets are unsuitable for operational monitoring.** In practise, verification of process performance requires checking of surrogate parameters.

WHO [2017]:

- Achieving specified turbidity targets at well-designed filtration plants that have been optimised to achieve particle removal is a critical component of demonstrating pathogen reductions (Table 4).

Treatment type	Turbidity target	Crypto reduction	Virus reduction
CFC+RGF	≤0.3NTU in 95%	3-log	2-log

Step B.3.2 - Protozoa Log Credit Compliance Criteria – CFC + RGF (enhanced individual filtration)


- To obtain 4.0 protozoa log credits for CFC + RGF used as a coagulation, clarification and filtration process, the following requirements must be met during periods when treated water is being produced:
 - a) *All water must pass through the full CFC and filtration process (no bypass or mixing of water without CFC + RGF);*
 - b) *The filters must be operated at a steady flow rate. Maximum rate of change of flow – 1.5%/minute;*
 - c) *Measurement of turbidity of the filtered water leaving each filter must satisfy the following conditions:*
 - i. *Shall be less than or equal to 0.1 NTU for at least 95% of each filter cycle. The filter cycle is the period between the filter being returned to supply following backwashing and being taken out of supply for backwashing;*
 - ii. *Individual filtrate shall not exceed 0.3 NTU for the duration of any 15-minute period;*
 - iii. *Individual filtrate shall not exceed 0.5 NTU for the duration of any 3-minute period; and*
 - iv. *Filter run to waste until below 0.1 NTU – filters shall be capable of directing filtered water to waste immediately following a backwash for a period of time until the filtrate turbidity value is below 0.1 NTU.*

- Protozoal compliance monitoring requirements for CFC + RGF are as follows (separation between data records must be less than 1-minute):

Parameter	Location	Frequency	Critical Control Point	Alarm	Compliance duration
Turbidity	Settled water	Continuous	>2.0NTU	>1.5NTU	Any 15-minute period
	Filtered water (individual)	Continuous	>0.1NTU	>0.08NTU	Any 15-minute period
	Filtered water (individual)	Continuous	>0.5NTU	>0.45NTU	Any 3-minute period
	Filtered water (individual)	Continuous	Settled water turbidity ≥ raw water turbidity		Any 3-minute period
Flow	Filtered water (individual)	Continuous	>design filtration rate m ³ /m ² /hr		Any 15-minute period
Headloss	Individual filter	Continuous	>0.25m	>0.20m	Any 1-minute period
Rate of change of filtration rate	Filter water (individual)	Continuous	>1.5% of filtration rate through each filter/minute		Any 1-minute period
Filter cycle	Individual filter	Continuous	>48hrs	>40hrs	Any filter cycle


IW has adopted the **Drinking Water Safety Plans approach** to develop a more **standardised** and **consistent** set of **Policies, Strategies, Specifications, Standard Operating Procedures, Planned Maintenance**, across the organisation.





IW Raw Water Monitoring Programme

RW UVT vs. Rainfall (River source)




- Strong correlation between rainfall and RW UVT (high rainfall = low UVT)
- Grab sampling provides incomplete picture (grab sampling 58.1% vs on-line 40%)

Grab Samples	UVT	Turbidity	DOC
23/03/2016	83.3	3.68	1.3
28/04/2016	83.8	0.54	1.3
30/06/2016	58.1	0.44	4.3
28/07/2016	73.4	19.8	2.8

DWSP Disinfection Control Measures

Disinfection Risk Control



Inactivation

Removal

Barrier 1: Bacteria and virus (≥4-log)

Eff Ct > Target Ct

Barrier 2: Maintain Barrier 1 (network)

>0.1mg/l at tap

Barrier 3: Protozoa (3-log) [UV]

UVI/UV RED > validation limit

Barrier 4: Protozoa (≥3-log) [CFC+RGF, SSF]

Turbidity < limit

IW WTP elimination capacity = 4.0B + 4.0V + (0 to 5.0)P

[Swedish WTP elimination capacity = (3.0 to 6.0)B + (3.0 to 6.0)V + (2.0 to 5.0)P]

Primary Disinfection - Pathogen Compliance Criteria

- Removal (filtered water)
 - Turbidity
 - <1.0ntu – 100%
 - 3-log Crypto <0.3ntu – 95%
 - 4-log Crypto <0.1ntu – 95%
- Chlorination
 - Primary (WTP final water) - adequate Ct
- UV
 - NSF, DVGW, ONORM -40mJ/cm2
 - USEPA – 3-log Crypto



Pathogen Compliance Review							
Irish Water Site:		County:					
Date:	21/01/2016	Data Source:	SCADA (1 minute intervals)				
		Date from:	21/12/2013 15:58				
		Date to:	21/12/2015 15:58				
		No. of days:	730	days			
Site Processes:	DAFF + UV + Chlorination		17520	hrs			
Source:	S3	Data period with plant operating:	12039	hrs			
		Theoretical total run time:	12363	hrs			
Primary disinfection process:	UV	Protozoa Log Credits:	5				
Note:							
Recorded SCADA Data Analysis							
* Outlier values excluded from dataset analysis							
	Values	Raw Flow (m3/s)	Raw Turbidity (ntu)	Raw pH	Treated Flow (m3/s)	Treated Turbidity (ntu)	
Max:	14.4	19.97	9.29	20.00	+5.00		
95th percentile	12.5	2.43	na	14.67	0.32		
Min:	0.1	0.00	3.92	0.01	0.00		
Ave:	11.0	1.19	6.88	11.31	0.12		
	Values	UVI (%)	UVI (mJ/cm2)	Residual Chlorine (mg/L)	Treated pH		
Max:	28.58	57.56	45.00	11.58			
5th percentile	0.09	28.42	0.46	na			
Min:	0.06	0.00	0.00	3.74			
Ave:	75.63	34.71	0.90	7.29			
CFC+RFG Removal Non-compliance (Step B.3.1 requirements not met when producing drinking water)							
Parameter	Compliance Criteria	No. of Events	No. of Days	Max. duration	Ave. duration	% of total data period	Data period (hrs)
Turbidity	> 0.3NTU any 15min period	369	200	24.7hrs	2.2hrs	6.8%	12039
	RW turb. < TW turb. [+0.1NTU]	254	131	7.8hrs	7.5hrs	0.2%	12039
Flow (TW)	> 11m3/hr any 15min period	1356	405	2.6days	4.0hrs	45.1%	12039
Headloss	< 0.25m any 1min period	-	-	-	-	-	-
Rate of change	< 1.5% any 1min period	-	-	-	-	-	-
Filter cycle	> 48 hours	-	-	-	-	-	-
UV Disinfection Non-compliance (Step B.3.5 requirements not met when producing drinking water)							
Parameter	Compliance Criteria	No. of Events	No. of Days	Max. duration	Ave. duration	% of total data period	Data period (hrs)
Turbidity	> 1.0NTU any 15min period	101	29	18hrs	3hrs	2.5%	12039
	> 2.0NTU any 3min period	90	20	7.8hrs	2.5hrs	1.9%	12039
Flow (TW)	> 11m3/hr any 15min period	1356	405	2.6days	4.0hrs	45.1%	12039
UVT	< [limit]% any 3min period	626	150	2.6days	3.4hrs	17.9%	12039
UVI or RED	< [limit] any 3min period	22	15	0.3hrs	0.1hrs	0.1%	4553
Chlorination Non-compliance (Step A.2 requirements not met when producing drinking water)							
Parameter	Compliance Criteria	No. of Events	No. of Days	Max. duration	Ave. duration	% of total data period	Data period (hrs)
Turbidity	> 1.0NTU for any 3min period	132	31	18hrs	2.3hrs	2.6%	12039
	> 2.0NTU for any 1min period	96	24	7.8hrs	2.3hrs	1.9%	12039
	RW turb. < TW turb. [+0.1NTU]	254	131	7.8hrs	7.5hrs	0.2%	12039
Flow (TW)	> 11m3/hr any 15min period	1356	405	2.6days	4.0hrs	45.1%	12039
Total Chlorine	< 0.4mg/L any 3min period	-	-	-	-	-	-
Residual Chlorine	< 0.5mg/L any 3min period	1253	333	2.7days	0.7hrs	6.8%	12039
Cl Contact Time	Effective Ct < Required Ct any period	Req. Ct	18	Eff. Ct	4.15	Effective Ct figure from Galway Disinfection Review 09-02-2015	
pH (TW)	> [max design pH] any 15min period	571	225	2.8days	3.4hrs	16.0%	12039
Plant Shutdown							
Ave. daily run time:	Denied using theoretical run time		16.9	hrs			
Parameter	Compliance Criteria	No. of Events	No. of Days	Max. duration	Ave. duration	% of total data period	Data period (hrs)
Turbidity	Non-compliance event > 7.1hrs	16	16	24.7hrs	13.3hrs	1.8%	12039
Flow	Non-compliance event > 7.1hrs	125	109	2.6days	15.9hrs	16.5%	12039
UVT	Non-compliance event > 7.1hrs	33	30	2.6days	20.4hrs	5.6%	12039
UVI	Non-compliance event > 7.1hrs	0	0	0days	0hrs	0.0%	4553
Residual Chlorine	Non-compliance event > 7.1hrs	10	10	2.7days	19.2hrs	1.6%	12039
pH	Non-compliance event > 7.1hrs	27	26	2.8days	22hrs	4.9%	12039
SCADA Data Gaps							
Parameter	Compliance Criteria	No. of Events	No. of Days	Max. duration	Ave. duration	% of total data period	Data period (hrs)
Missing data for any 1min interval		3,017	471	5.4days	6.4mins	3.2%	17520
> 1hr duration		4	4	5.4days	18.9hrs	0.4%	17520

CFC+RFG Review - Example

Values	Raw Flow (m3/hr)	Raw Turbidity (NTU)	Raw pH	Treated Flow (m3/hr)	Treated Turbidity (NTU)
Max.	30.0	19.99	11.99	48.3	+5.00
95th percentile	28.0	0.93	na	27.6	0.62
Min.	0.1	0.26	5.10	0.0	0.00
Ave.	25.9	0.58	6.80	20.4	0.21

Values	UVT (%)	UVI (W/m2)	Residual Chlorine (mg/L)	Treated pH
Max.	100.0	66.0	3.81	9.36
5th percentile	79.7	18.6	0.52	na
Min.	29.2	0.0	0.00	3.45
Ave.	88.6	35.2	0.87	7.23

CFC+RFG Removal Non-compliance (Step B.3.1 requirements not met when producing drinking water)							
Parameter	Compliance Criteria	No. of Events	No. of Days	Max. duration	Ave. duration	% of total data period	Data period (hrs)
Turbidity	> 0.3NTU any 15min period	1737	379	2.2days	1.8hrs	19.6%	16167
	RW turb. < TW turb. [+0.1NTU]	3163	231	3.1days	0.3hrs	4.9%	16167
Flow (TW)	> 30m3/hr any 15min period	0	0	0hrs	0hrs	0.0%	16167
Headloss	< 0.25m any 1min period	-	-	-	-	-	-
Rate of change	< 1.5% any 1min period	-	-	-	-	-	-
Filter cycle	> 48 hours	-	-	-	-	-	-

DWSP Water Quality Control Measures

Physical/Chemical Risk Control

Removal

Barrier 5: Interruption to supply	supply > demand
Barrier 6: DBP (THMs)	$\leq 100 \mu\text{g/l}$ at tap
Barrier 7: Lead	$\leq 10 \mu\text{g/l}$ at tap
Barrier 8: Pesticides	$\leq 0.5 \mu\text{g/l}$ at tap
Barrier 9: Nitrates	$\leq 50 \text{mg/l}$ at tap
Barrier 10: Aluminium	$\leq 200 \mu\text{g/l}$ at tap
Barrier 11: Iron	$\leq 200 \mu\text{g/l}$ at tap
Barrier 12: Manganese	$\leq 50 \mu\text{g/l}$ at tap
Barrier 13: Taste and odour	acceptable at tap
Barrier 14: Pollution of environment	\leq discharge limit
Barrier 15: Other	\leq limit at tap



a Water Quality Risk Analysis

2014-16
751no.
WSZs

Treated Water TTHM Risk Prioritisation		TTHM (maximum concentration) [µg/L]		
		100 - 200	200 - 300	>300
TTHM (average concentration) [µg/L]	<100	2	2	3
	100 - 150	2	3	4
	>150	3	4	5



TTHM Risk	No. of WSZs	Existing CFC
5	7	1
4	7	2
3	11	3
2	91	41
Total	116	47

- Existing WTP deficiencies:

- 1) No DBP precursor removal process (69no. – 60%);
- 2) Existing DBP removal and/or disinfection process not optimised (47no. – 40%);
- 3) Network exceedance after booster chlorination.

Disinfection Policy Comparison

Irish Water

- Removal (filtered water)
 - *Turbidity*
 - <1.0ntu – 100%
 - 3-log Crypto <0.3ntu – 95%
 - 4-log Crypto <0.1ntu – 95%
 - *TTHM_t < 40 to 80µg/l (t > 24hrs)*
- Chlorination (WTP final water)
 - *WTP final water > 0.5mg/l*
 - *Customer tap = detectable FCR*

Scottish Water


- Removal (WTP final water)
 - *Turbidity*
 - <1.0ntu – 100%
 - <0.5ntu – 99%
 - <0.4ntu – 95%
 - *TTHM < 40µg/l*
- Chlorination (WTP final water)
 - *WTP final water > 0.5mg/l*
 - *Reservoir outlet > 0.25mg/l*
 - *Customer tap = detectable FCR*

CFC Optimisation

Draft IW Jar Testing and THMFP Specification


1) Preliminary design stage (before preparation of documents):

- a. Jar test:
 - i. pH/alkalinity control (acid or base)
 - ii. coagulation (alum and PACL)
 - iii. flocculation (no polymer)
 - iv. sedimentation
 - v. filtration
- b. THMFP (8mg/l Cl dose with THM measured at 72-hrs)



2) Contractor design stage (after contract award):

- a. Jar test:
 - i. pH/alkalinity control (acid or base)
 - ii. coagulation (alum and PACL)
 - iii. flocculation (polymer)
 - iv. sedimentation
 - v. filtration
- b. THMFP (8mg/l Cl dose with THM measured at 72-hrs)



3) Jar testing and THMFP testing frequency:


- a. RW UVT $\pm 5\%$ change;
- b. RW true colour ± 10 PtCo unit change; or
- c. RW turbidity ± 10 NTU unit change

Risk Assessment

Jar Testing and THMFP


THM Monitoring - 2007 to 2014

No. of Samples	No. of Samples > 100µg/L	Average concentration (µg/L)	Max. concentration (µg/L)
81	57	159	312





THM Monitoring - 2007 to 2014

No. of Samples	No. of Samples > 100µg/L	Average concentration (µg/L)	Max. concentration (µg/L)
32	6	69	132




	RW
Turbidity (NTU)	0.53
TOC (mg/l)	7.87
UVT (%)	52.8



	RW
Turbidity (NTU)	0.45
TOC (mg/l)	13.76
UVT (%)	24.4




Portumna WSS – Jar Test THMFP



	RW	TW (JT)	% Improvement
Turbidity (NTU)	0.53	0.13	75%
TOC (mg/l)	7.87	4.43	44%
UVT (%)	52.8	87.6	66%

RH, EPS 2016



	RW	TW (JT)	% Improvement
Turbidity (NTU)	0.53	0.18	66%
TOC (mg/l)	7.87	3.77	52%
UVT (%)	52.8	87.6	66%

RH, EPS 2016

- PACL removes more TOC;
- Alum removes more THM precursors.



Portumna WSS – CFC Upgrade

TTHM Monitoring - 2007 to 2014


No. of Samples	No. of Samples > 100µg/L	Average concentration (µg/L)	Max. concentration (µg/L)
81	57	159	312

	RW	TW (JT)	% Improvement
Turbidity (NTU)	0.53	0.13	75%
TOC (mg/l)	7.87	4.43	44%
UVT (%)	52.8	87.6	66%

	RW TOC (mg/l)	TW TOC (mg/l)	% improvement
14/02/2017	8.06	3.67	55%
16/02/2017	9.00	4.05	55%




Jar Testing and THMFP



RW UVT	Alum dose	Sulphuric acid dose	THM (µg/l)	Alum + acid chemical unit OPEX/m3	Alum + acid chemical OPEX/day	Alum + acid chemical OPEX/yr
63.6	160	0	83.3	€0.02	€504	€183,960
61.6	160	70	79.46	€0.02	€725	€264,443
57.8	200	0	68.76	€0.02	€630	€229,950
52.7	220	70	68.7	€0.03	€914	€333,428
47.5	160	110	93.8	€0.03	€851	€310,433
40.5	260	100	75.75	€0.04	€1,134	€413,910

WTP Upgrade Solutions



Chlorine dose	<3.0mg/l	> 3.0mg/l	
Max TTHMs	< 160µg/l	> 160µg/l	
TOC			>12mg/l
CFC+RGF		← Permanent →	
In-tank aeration	← Permanent →	← Interim →	
PAC+CFC+RGF			← Permanent →

IW Coagulation Control Guidelines

Coagulation Control Upgrade Rollout

1. Upgrading works (improvements to coagulation control) must pass the following business test:
 - a. *Reduce DWSP risk (i.e. **effect Barriers 4 and 6**); and/or*
 - b. *Economic (**payback < 5-years**)*
2. In addition, Process Ops team will carryout a review of proposed upgrading works and make a recommendation, before AS approval.

Example – AMP business test


WTP 1

Barrier		RA - 25	RA - 20	RA - 16	OM
1	B + V	1	1		● 2
2	Tap				● 2
3	UV				n/a
4	CFC+RGF	7	3		● 2
5	Supply				● 3
14	Pollution				● 4



WTP 2

Barrier		RA - 25	RA - 20	RA - 16	OM
1	B + V	1	1		● 2
2	Tap				● 2
3	UV				n/a
4	CFC+RGF	1		1	● 5
5	Supply				● 4
14	Pollution				● 2



SCM - Design

1. SCM correlates with turbidity/organic removal, especially when charge neutralization is the dominant coagulation mechanism.

Key benefit – provides information more rapidly than a jar test and under most conditions will inform Operator in which direction the coagulation dose should be adjusted.

Increasing negative signal indicates excess of negatively charged particles, {i.e. deterioration in raw water.}

2. Proper function of SCM is dependent on proper installation, in particular, location of sampling point. A sample point free of abrasive grit and resistant to clogging must be assured.

SCM – Design cont.

3. The design of SCMs under the following conditions must be referred to Asset Strategy(Process Optimisation) for prior approval:
 - a. Stable raw waters conditions (lakes) [less likely to save appreciable amounts of chemicals, chemical reduction low (average 15%) – high payback period];
 - b. High coagulant dose (alum dose >150mg/l);
 - c. High alkalinity (>100mg/l);
 - d. Very low pH and turbidity (i.e. sweep flocculation coagulation is required);
 - e. UVA/UVT for forward feed control (raw water turbidity > 8.0NTU);
 - f. Use of lime for pH adjustment;
 - g. Recirculation of liquid residuals (filter backwash, etc.). Residual metal hydroxides are positively charged;
 - h. Occasional use of powdered activated carbon (PAC); and
 - i. Control of dose rates for high molecular weight polymers (coagulant aids or flocculants).

SCM - Installation and commissioning


1. Manufacturer's assistance is required in installation and establishment of correct sampling point, (i.e. evaluation of 3 or more sampling locations may be required to find best sampling point);
2. Manufacturer's assistance is required during commissioning period (min. 12 months). Commissioning period should cover periods when coagulation difficulties will be encountered, (i.e. high/low – turbidity, organics, temperature, etc.);
3. SCM set point should be established by initial use of jar tests, followed by observation of plant performance as a function of SCM reading, (i.e. increasing/reducing coagulant dose vs settled water quality [turbidity, true colour or UVA/UVT]); and
4. Manufacturer to provide cost/benefit analysis and performance assessment report (before and after SCM installation):
 - a. *Plant operational data for stable and transient conditions (flow, chemical use, raw and settled water quality [pH, temperature, turbidity, true colour and/or UVA/UVT]); and*
 - b. *Plant and equipment failure and out of service.*

SCM - Operation and maintenance

1. **SCM is not a substitute for good operation and maintenance.**
 Periodic comparison with jar tests is essential. The set point should be re-evaluated periodically to ensure optimum settled water quality (turbidity, true colour or UVA/UVT.) Set points will become less accurate with large variations in temperature, turbidity, organics, colour, pH, etc. Set points may vary monthly, day and night, etc.;
2. **Establishment of preventative maintenance schedule is key to performance.** Waiting for signs that instrument is dirty may result in the production of poor water quality. Experience indicates that cleaning requirements could vary from 2 days to 3 months, depending on concentration of raw water contaminants and type of coagulant used;
3. High iron or manganese in raw water may increase operational difficulties; and
4. Lime addition may increase operational difficulties.

Draft CFC Specification amendments




1. CFC control process –



Draft CFC Specification amendments cont.

2. Pg 79: Control mechanism:

- a) *Manual or automatic (preferred option);*
- b) *Feed forward – turbidity, UVA/UVT (or true colour)*
- c) *Feedback – SCM (optional)*
- d) *Tables 31 to 33:*

Coagulation Control	Turbidity	TOC	Coagulation pH	Alkalinity
Turbidity 	> 8ntu	<2		
UVA/UVT 	< 8ntu	>2		
SCM 			< 7.5	> 100mg/l

3. Pg 80+: Replace SUVA with UVA/UVT

4. Protozoa log credit compliance criteria - CFC:

- To obtain protozoa log credits for CFC + RGF used as a coagulation, clarification and filtration process, the following requirements must be met during periods when treated water is being produced:
 - a) *All water must pass through the full CFC and filtration process (no bypass or mixing of water without CFC + RFG);*
 - b) *The clarifiers must be operated at a steady flow rate;*
 - c) *Measurement of turbidity of the clarified water must satisfy the following conditions:*
 - i. Shall be less than or equal to 2.0 NTU for at least 95% of each 24-hour period.
- Protozoal compliance monitoring requirements for CFC process (part of CFC+RGF) are as follows (separation between data records must be less than 1-minute):

Parameter	Location	Frequency	Critical Point	Control	Alarm	Compliance duration
Turbidity	Raw water	Continuous	>8.0NTU		>7.0NTU	Any 15-minute period
	Clarified water	Continuous	>2.0NTU		>1.5NTU	Any 15-minute period
pH	Before coagulation	Continuous	>Target pH		>0.8 Target pH	Any 15-minute period
UVT/UVA	Raw water	Continuous	< Coag design limit		< 1.2 Coag design limit	Any 15-minute period
SCM (optional)	After coagulation	Continuous	< SCM set-point		< 1.2 SCM set-point	Any 15-minute period
Flow	Raw water	Continuous	>maximum design flow m ³ /hr		>maximum design flow m ³ /hr	Any 15-minute period

CFC Control Summary

CFC Control

RW
UVT/UVA,
turbidity or
true colour

Clarified
turbidity
and SCM
(optional)




RW pH and
alkalinity

Coagulation
recipe



TOC/
DOC SUVA

For info only



Jar test +
THMFP

